

(1) CERTIFICATE

- (2) No. of the Certificate: **ZP/B181/25-PZ**
- (3) Product: **Anchor device type A**
Type: ABS-Lock® Falz VI
- (4) Manufacturer: **ABS Safety GmbH**
- (5) Address: **Gewerbering 3, 47623 Kevelaer, GERMANY**
- (6) The design of this product and any acceptable variation thereto are specified in the appendix to this certificate.
- (7) The Certification Body of DEKRA Testing and Certification GmbH certifies that this product complies with the requirements of the test regulations listed under item 8 below. The test results are recorded in report PB 25-223.
- (8) The requirements are assured by compliance with
DIN EN 795:2012 **DIN CEN/TS 16415:2017**
- (9) This certificate relates only to the design and tests of the specified product in accordance to the contemplated requirements. Further requirements applied to the manufacturing process and supply of this product, are not covered by this certificate.
- (10) The manufacturer is authorised to apply the mark of conformity to the products that conform to the types examined.
- (11) This certificate is valid until 2031-01-11.

DEKRA Testing and Certification GmbH
Bochum, 2026-01-12

Signed: Brumm
Managing director

We confirm the correctness of the translation from the German original.
In the case of arbitration only the German wording shall be valid and binding.



Managing director



TRANSLATION

- (12) Appendix to
- (13) **Certificate**
ZP/B181/25-PZ
- (14) 14.1 Subject and type
Anchor device type A
Type: ABS-Lock® Falz VI

14.2 Description

The anchor device of type ABS-Lock® Falz VI (Fig. 1) is used to protect maximum three people against falls from a height; it is intended for being mounted on round seam profiles of sufficient strength. The anchor device is fastened on the roof profiles by means of either six or three two-part aluminium profile clamps which are adjusted to the contour of the round seam. The profile clamps are fixed by two screws (M10). The base rail of the anchor device is made of two-edged sheets with two centrally placed long holes each. The base rail provides an H-shaped frame construction. The cross rail and the profile clamps are connected by means of an M16 hexagonal screw with the pertinent hexagonal nuts and U-shaped washers. The long holes provided allow to adjust the anchor device to the individual coultter width between 305 mm and 500 mm of the surface where the device is mounted.

A lug in the middle of the anchor device is used as an attachment eyelet. Instead of the eyelet, appropriate wire rope system components can also be mounted. The anchor device is intended for bearing loads being exerted from any direction parallel to the structure surface; it is made of aluminium and corrosion-resistant steel.



Bild 1: Anchor device, type: ABS-Lock® Falz VI

- (15) Report
PB 25-223, 2026-01-12